

**LEAD IN DRINKING WATER SAMPLING
REPORT
PRIME TIME HEAD START AT JEANERETTE
600 Ira Street, Jeanerette
Iberia Parish, Louisiana**

Prepared for:

Prime Time, Inc.

Prepared by:

**Matrix New World Engineering, Land Surveying
and Landscape Architecture, PC**

6717 Complex Drive
Baton Rouge, LA 70809
225.508.4792
www.mnwe.com

MATRIX**NEW****WORLD**
A  **TRUE ENVIRONMENTAL** COMPANY

Date:

November 17, 2025

Matrix Project No.: 25-0710

TABLE OF CONTENTS

1.0 INTRODUCTION	1
1.1 Background	1
1.2 Purpose and Scope	2
2.0 REVIEW AND SAMPLE PLANNING	3
2.1 Prior Sampling Review	3
2.2 Amended Fixtures	3
3.0 SAMPLING EVENT	4
3.1 Procedures	4
3.2 Sampling Event	4
3.3 Laboratory Analysis	5
4.0 SAMPLE RESULTS	6
5.0 CONCLUSIONS	7

TABLES

Table 4.1 Sample Results

APPENDICES

Appendix A Facility Maps

Appendix B ID Codes and Abbreviations

ATTACHMENTS

Attachment 1 Analytical Laboratory Reports

1.0 INTRODUCTION

Prime Time, Inc. (Prime Time), retained Matrix New World Engineering (Matrix) to provide lead in drinking water sampling services at three child care facilities operated by Prime Time in Lafayette and Iberia Parishes. Matrix has prepared this Lead in Drinking Water Sampling Report (the Report) for Prime Time following the sampling of water at the Prime Time Head Start at Jeanerette facility (the Facility) to determine the potential presence and concentration of lead in drinking water.

This Report provides a summary of the activities performed by Matrix and the results of the analytical testing.

1.1 Background

Lead is a naturally occurring element with some beneficial uses, but it can be toxic to humans and animals. Lead can be found in the air, soil, water, and in other materials (e.g. paint, batteries). Lead was a common material used in plumbing materials for many years and can enter drinking water through corrosion. According to the Environmental Protection Agency (EPA), the most common sources of lead in drinking water are lead pipes, faucets, and fixtures. Lead service lines are more likely to be found in buildings built before 1986. Among buildings without lead pipes, the most common sources of lead in drinking water are brass or chrome-plated brass faucets and plumbing with lead solder (melted metal or alloy used to join pieces of metal). Additionally, some drinking water fountains with lead-lined tanks and other plumbing fixtures not intended for drinking water (e.g. hoses, spigots, hand washing sinks) may also be sources of lead in drinking water. The amount of lead that enters drinking water from these sources is affected by many factors, including: the chemistry of the water, the amount of lead the water is in contact with, the temperature of the water, the amount of wear in the pipes, how long water stays in the pipes, and the presence of protective scales or coatings inside the plumbing materials.

The Safe Drinking Water Act requires EPA to determine the level of contaminants in drinking water at which no adverse health effects are likely to occur with an adequate margin of safety. EPA has set the maximum contaminant level goal for lead in drinking water at zero because lead is a toxic metal that can be harmful to human health even at low exposure levels. EPA also set an action level for lead in drinking water at 15 parts per billion (ppb). Lead is persistent, and it can bioaccumulate in the body over time.

According to the Center for Disease Control and Prevention (CDC) and the EPA, young children, infants, and fetuses are particularly vulnerable to lead because the physical and behavioral effects of lead occur at lower exposure levels in children than in adults. In children, low levels of exposure have been linked to damage to the central and peripheral nervous system, learning disabilities, shorter stature, impaired hearing, and impaired formation and function of blood cells. The most important step in protecting children from these effects is preventing lead exposure before it occurs by removing lead hazards from their environment.

The EPA has determined even when water entering a facility meets all federal and state safe drinking water standards for lead, older plumbing materials in schools and child care facilities may contribute to elevated levels of lead in drinking water. Additionally, due to the intermittent water use patterns, schools and child care facilities are more likely to have a higher potential for lead to enter drinking water as water remains in contact with lead plumbing materials for longer. However, the only way to know if lead is present in drinking water is to test.

In order to help schools and child care facilities implement a voluntary program to reduce lead in drinking water, the EPA developed a guide for training, testing, and taking action called the 3Ts for Reducing Lead in Drinking Water in Schools and Child Care Facilities (the 3Ts). The 3Ts manual was revised in 2018 and provides information and resources to assist schools and child care facilities in identifying potential problems, implementing targeted remediation efforts, and communicating with parents, teachers, and the public. The EPA also developed a toolkit of resources to support the 3Ts. The 3Ts manual and toolkit can be found at <https://www.epa.gov/ground-water-and-drinking-water/3ts-reducing-lead-drinking-water>.

The Facility was previously sampled for lead in drinking water under the Water Infrastructure Improvements for the Nation (WIIN) Grant Lead Testing Program administered by the Louisiana Department of Health (LDH). Under this program, the Facility's water fixtures were sampled on March 23, 2023, and a Final Sampling Report (the WIIN Report) dated April 5, 2023, was developed for the Facility summarizing the activities and analytical results.

1.2 Purpose and Scope

Matrix reviewed the WIIN Report dated April 5, 2023, which summarized the previous lead in drinking water sampling at the Facility. After review of the fixtures previously sampled and in consultation with a representative of the Facility, Matrix developed a list of fixtures to be sampled at the Facility. Matrix sampled the applicable water fixtures at the Facility in accordance with EPA's 3Ts for Reducing Lead in Drinking Water in Schools and Child Care Facilities. A summary of the sampling event is included in Section 3 below. After receiving the laboratory analytical reports (**Attachment 1**), Matrix reviewed the results and developed this summary Report.

2.0 REVIEW AND SAMPLE PLANNING

Matrix reviewed the results of the prior sampling conducted at the Facility and the WIIN Report dated April 5, 2023. Using the WIIN Report as a guide and in conjunction with a Prime Time representative, Matrix determined which fixtures were appropriate to sample in accordance with the 3T's.

2.1 Prior Sampling Review

The Facility was previously sampled for lead in drinking water on March 23, 2023, and the results were presented in the WIIN Report dated April 5, 2023. In the WIIN Report, each fixture was assigned a specific fixture ID using the following method:

(Building) - (Floor) – (Room # or Name) – (Fixture Type and Location)

The WIIN Report included a facility map indicating the fixture locations and water main location and a list of codes and abbreviations used in the fixture and sample IDs.

Matrix retained the fixture IDs from the WIIN Report for this sampling event. An updated map is included in **Appendix A**, and a copy of the list of codes and abbreviations used in the fixture and sample IDs is included in **Appendix B**.

2.2 Amended Fixtures

After review of the WIIN Report, Matrix discussed the water fixtures at the Facility with the Prime Time representative. During the discussions, the following information was provided:

- The water for the bulk water dispensers is already filtered and contaminants removed by the retailer. Additionally, results from the prior sampling were all non-detect (less than 0.500 ppb) for these fixtures. For these reasons, the four bulk water dispensers (eight previously sampled fixtures) do not need to be resampled.
- Two water coolers were noted as being out-of-service in the WIIN Report. These fixtures remain out-of-service and do not need to be sampled.

After review the information provided, Matrix concluded 16 fixtures at the Facility should be sampled.

3.0 SAMPLING EVENT

Matrix coordinated with the Facility to schedule the sampling event. Matrix conducted sampling at the Facility on October 24, 2025, in accordance with the sampling guidance provided in the EPA's 3Ts for Reducing Lead in Drinking Water in Schools and Child Care Facilities.

3.1 Procedures

Matrix ensured, through scheduling and communication with facility representatives, that the water was unused in the Facility's pipes/fixtures for a minimum of eight, but not more than eighteen hours prior to initiating sampling. Additionally, Matrix ensured that first-draw samples were collected before the facility opened and before any water was used at the Facility.

All samples were collected in a 250 milliliter (mL) wide-mouth bottle utilizing a two-step process.

- Step 1- First Draw or Primary Samples (P) - This sample was collected immediately after opening the faucet/valve without allowing any water to go to waste.
- Step 2- Flush Samples (F) - This sample was collected after running (flushing) the water for 30 seconds.

Matrix began the sampling event in the Facility's kitchen. All first draw and flush samples were collected in the kitchen prior to sampling any other areas of the facility. Following the kitchen samples, Matrix began collecting first draw samples of the other fixtures in the area closest to where the water main enters the facility and working away from that point. After first draw samples were collected, Matrix collected the flush samples utilizing the same pattern.

Matrix noted the time of each sample on the laboratory chain-of-custody forms included in **Attachment 1**. Sample bottles were packaged according to the sampling guidance.

3.2 Sampling Event

Matrix conducted sampling of the Facility on October 24, 2025. During the sampling event, Matrix was unable to sample the following fixtures:

- The faucet and sink bubbler on the classroom sink in Room 132, fixture IDs 1-1-132-F and 1-1-132-SB, had been removed and were not sampled.

Matrix ultimately collected primary and flush samples for 14 fixtures. Each sample was identified using the fixture ID plus "P" or "F" for primary or flush.

(Building) - (Floor) – (Room # or Name) – (Fixture Type and Location) - (Primary/Flush)

A comprehensive list of the fixtures sampled and the sample results is included in Table 4.1. A facility map indicating the fixture locations is included in **Appendix A**.

3.3 Laboratory Analysis

Samples collected by Matrix were submitted to Waypoint Analytical (Waypoint). Waypoint is certified by the LDH Office of Public Health as a chemical laboratory/drinking water, a laboratory meeting the requirements contained within the laboratory certification regulations (LAC 48:V.Chapter 80). Waypoint analyzed the samples for lead using the EPA Method 200.8 and a Reporting Limit of 0.500 micrograms per liter ($\mu\text{g/L}$).

4.0 SAMPLE RESULTS

A summary of the laboratory analytical results is included in Table 4.1 below.

Sample results were reported by the lab in micrograms per liter (µg/L) which is equivalent to parts per billion (ppb).

TABLE 4.1 SAMPLE RESULTS

Fixture ID	Location	Fixture Type	Primary Sample (ppb)	Flush Sample (ppb)
1-1-KIT-KF(L)	Kitchen	Faucet	1.09	1.33
1-1-KIT-KF(R)	Kitchen	Faucet	0.557	0.558
1-1-103-CF	Classroom 103	Faucet	3.56	<0.500
1-1-FAC111A-F	Faculty Workroom 111A	Faucet	0.513	<0.500
1-1-104-CF	Classroom 104	Faucet	2.32	<0.500
1-1-105-CF	Classroom 105	Faucet	0.710	<0.500
1-1-106-CF	Classroom 106	Faucet	1.13	<0.500
1-1-107-CF	Classroom 107	Faucet	2.33	<0.500
1-1-GBath115-BF(L)	Girls Bathroom 115	Faucet	1.07	0.744
1-1-BBath116-BF	Boys Bathroom 116	Faucet	2.66	2.16
1-1-110-CF	Classroom 110	Faucet	4.16	<0.500
1-1-112-CF	Classroom 112	Faucet	6.27	0.536
1-1-114-CF	Classroom 114	Faucet	5.45	<0.500
1-1-HAL(by126/127)-BF(L)	Hallway (by Bathrooms 126 and 127)	Faucet	0.643	<0.500


5.0 CONCLUSIONS

Matrix performed sampling at the Prime Time Head Start at Jeanerette Facility to determine the potential presence and concentration of lead in drinking water. Matrix collected 28 samples from 14 fixtures at the Facility. Of the 14 fixtures sampled, lead was detected in the primary samples for all the fixtures, but lead was only detected in five flush samples. All results were below the action level set by EPA (15 ppb).

Through use of these sample results and information included in resources such as EPA's 3Ts for Reducing Lead in Drinking Water, the Facility can continue to implement practices to reduce potential lead exposure to children.

APPENDIX A
FACILITY MAP

Map 1 of 1
 Facility Layout



APPENDIX B

ID CODES AND ABBREVIATIONS

Fixture ID Naming

(Building) – (Floor) – (Room# or Name) – (Fixture Type and location) – (Primary or Flush)

Room Name Codes

Kitchen	KIT	Hallway	HAL
Bathroom	BATH	Office	OFF
Cafeteria	CAF	Exterior	EXT
Locker room	LR	Teacher's Lounge	TEA
Gymnasium	GYM	Entryway	ENT
Nurse or Nursery	NUR	Concessions	CON
Library	LIB	Facility Workroom	FAC

Fixture Type Codes

Water Cooler Fountain	WC	Bubbler	BU
Faucet (not listed otherwise)	F	Sink Bubbler	SB
Classroom Faucet (sink)	CF	Kitchen Faucet (sink)	KF
Bathroom Faucet (sink)	BF	Nurse's Office Faucet/Sink	NF
Janitor Closet Faucet/Sink	JF	Kitchen Pot Filler	PF
Trough Faucet	TF	Shower Head	SH
Ice Machine	IM	Bottle Filler	BTL
Water Dispenser	WD	Portable Sink	PS
Sprayer/Spray Nozzle	S		

Fixture Location

Left	L	Middle Left	ML
Right	R	Middle Right	MR
Middle	M		

Primary or Flush

Primary- The first water to exit the fixture to fill the first sample bottle	P
Flush- Sample following the 30 second flush	F

ATTACHMENT 1
ANALYTICAL LABORATORY REPORTS



11/10/2025

Matrix New World Engineering
Ms. Dawn Brown
6717 Complex Drive
Baton Rouge, LA, 70809

Ref: Report Number: 25-297-0022
Project Description: Prime Time Head Start at Jeanerette

Dear Ms. Dawn Brown:

Waypoint Analytical Louisiana, Inc. received sample(s) on 10/24/2025 for the analyses presented in the following report. The above referenced project has been analyzed per your instructions. Unless otherwise noted, the analyses were performed in our laboratory in accordance with Standard Methods, The Solid Waste Manual SW-846, EPA Methods for Chemical Analysis of Water and Wastes and /or 40 CFR part 136.

Certain parameters (chlorine, pH, dissolved oxygen, sulfite...) are required to be analyzed within 15 minutes of sampling. Usually, but not always, any field parameter analyzed at the laboratory is outside of this holding time. Refer to sample analysis time for confirmation of holding time compliance. Analyses reported which indicate "Field" for these parameters were analyzed by the client in the field. Results for solid samples are reported on an as received or "wet weight" basis unless otherwise specified.

The analytical data has been validated using standard quality control measures performed as required by the analytical method. Quality Assurance, method validations, instrumentation maintenance and calibration for all parameters (NELAP and non-NELAP) were performed in accordance with guidelines established by the USEPA (including 40 CFR 136 Method Update Rule May 2021) and NELAC unless otherwise indicated. Any parameter for which the laboratory is not officially NELAP accredited is indicated by a '~' symbol. These are not included in the scope because NELAP accreditation is either not available or has not been applied for. Additional certifications may be held/are available for parameters, where NELAP accreditation is not required or applicable. A full list of certifications is available upon request.

All quality control measures undertaken in accordance with Waypoint Analytical Louisiana, Inc. CompQAP990807A and revisions under the terms of the Louisiana Environmental Laboratory Accreditation Program (Certificate #02041) are within acceptance ranges established in that document with the exception of the items indicated and/or discussed in a Case Narrative.

The results are shown on the attached analysis sheet(s). Be aware that the time analyzed for certain samples (e.g. - BOD, CBOD, etc.) refer to the time the sample batch was begun and not necessarily to the time an individual sample was begun. Thank you for allowing Waypoint Analytical Louisiana, Inc. to serve you. Should I be of further assistance, if you have any questions or need additional information please contact me or client services.

Sincerely,

Amy Jackson
Project Manager

Laboratory's liability in any claim relating to analyses performed shall be limited to, at laboratory's option, repeating the analysis in question at laboratory's expense, or the refund of the charges paid for performance of said analysis. This report may be reproduced in full only with the written permission of the laboratory and/or the entity to which it is addressed. Results contained herein relate only to the sample(s) submitted to the laboratory.



Certification Summary

Laboratory ID: WP MLA: Waypoint Analytical Louisiana, Inc., Marrero, LA

State	Program	Lab ID	Expiration Date
Georgia	State Program	02041	06/30/2026
Louisiana	State Program - NELAP	02041	06/30/2026

Laboratory ID: WP MTN: Waypoint Analytical, LLC. (Memphis), Memphis, TN

State	Program	Lab ID	Expiration Date
Alabama	State Program	40750	11/04/2025
Arkansas	State Program	88-00650	02/06/2026
California	State Program	2904	06/30/2026
Florida	State Program - NELAP	E871157	06/30/2026
Georgia	State Program	C044	11/14/2025
Georgia	State Program	04015	06/30/2025
Illinois	State Program - NELAP	200078	10/31/2026
Kentucky	State Program	KY90047	12/31/2025
Kentucky	State Program	80215	06/30/2026
Kentucky	State Program	KY90047	12/31/2025
Louisiana	State Program - NELAP	LA037	12/31/2025
Louisiana	State Program - NELAP	04015	06/30/2026
Mississippi	State Program	MS	11/14/2025
North Carolina	State Program	47701	07/31/2026
North Carolina	State Program	415	12/31/2025
Oklahoma	State Program - NELAP	9311	12/31/2025
Pennsylvania	State Program - NELAP	68-03195	05/31/2026
South Carolina	State Program	84002	06/30/2026
Tennessee	State Program	02027	08/11/2028
Texas	State Program - NELAP	T104704180	09/30/2026
Virginia	State Program	00106	06/30/2026
Virginia	State Program - NELAP	460181	09/30/2026

Sample Summary Table

Report Number: 25-297-0022
Client Project Description: Prime Time Head Start at Jeanerette

Lab No	Client Sample ID	Matrix	Date Collected	Date Received	Method	Lab ID
76441	1-1-KIT-KF(L)-P	Aqueous	10/24/2025 07:00	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76442	1-1-KIT-KF(R)-P	Aqueous	10/24/2025 07:02	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76443	1-1-103-CF-P	Aqueous	10/24/2025 07:04	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76444	1-1-FAC111A-F-P	Aqueous	10/24/2025 07:06	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76445	1-1-104-CF-P	Aqueous	10/24/2025 07:08	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76446	1-1-105-CF-P	Aqueous	10/24/2025 07:10	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76447	1-1-106-CF-P	Aqueous	10/24/2025 07:12	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76448	1-1-107-CF-P	Aqueous	10/24/2025 07:14	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76449	1-1-GBath115-BF(L)-P	Aqueous	10/24/2025 07:16	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76450	1-1-BBath116-BF-P	Aqueous	10/24/2025 07:18	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76451	1-1-110-CF-P	Aqueous	10/24/2025 07:20	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76452	1-1-112-CF-P	Aqueous	10/24/2025 07:22	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76453	1-1-114-CF-P	Aqueous	10/24/2025 07:24	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76454	1-1-HAL(by126/127)-BF(L)-P	Aqueous	10/24/2025 07:26	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN

Summary of Detected Analytes

Project: Prime Time Head Start at Jeanerette

Report Number: 25-297-0022

Client Sample ID Method	Lab Sample ID Parameters	Result	Units	Report Limit	Analyzed	Qualifiers
1-1-KIT-KF(L)-P	A 76441					
EPA-200.8 (DW)	Lead	1.09	µg/L	0.500	11/05/2025 17:19	
1-1-KIT-KF(R)-P	A 76442					
EPA-200.8 (DW)	Lead	0.557	µg/L	0.500	11/05/2025 17:21	
1-1-103-CF-P	A 76443					
EPA-200.8 (DW)	Lead	3.56	µg/L	0.500	11/05/2025 17:31	
1-1-FAC111A-F-P	A 76444					
EPA-200.8 (DW)	Lead	0.513	µg/L	0.500	11/05/2025 17:33	
1-1-104-CF-P	A 76445					
EPA-200.8 (DW)	Lead	2.32	µg/L	0.500	11/05/2025 17:36	
1-1-105-CF-P	A 76446					
EPA-200.8 (DW)	Lead	0.710	µg/L	0.500	11/05/2025 17:38	
1-1-106-CF-P	A 76447					
EPA-200.8 (DW)	Lead	1.13	µg/L	0.500	11/06/2025 09:26	
1-1-107-CF-P	A 76448					
EPA-200.8 (DW)	Lead	2.33	µg/L	0.500	11/06/2025 09:29	
1-1-GBath115-BF(L)-P	A 76449					
EPA-200.8 (DW)	Lead	1.07	µg/L	0.500	11/06/2025 09:31	
1-1-BBath116-BF-P	A 76450					
EPA-200.8 (DW)	Lead	2.66	µg/L	0.500	11/06/2025 09:34	
1-1-110-CF-P	A 76451					
EPA-200.8 (DW)	Lead	4.16	µg/L	0.500	11/06/2025 09:36	
1-1-112-CF-P	A 76452					
EPA-200.8 (DW)	Lead	6.27	µg/L	0.500	11/06/2025 09:44	
1-1-114-CF-P	A 76453					
EPA-200.8 (DW)	Lead	5.45	µg/L	0.500	11/06/2025 09:47	
1-1-HAL(by126/127)-BF	A 76454					
EPA-200.8 (DW)	Lead	0.643	µg/L	0.500	11/06/2025 09:49	

Project Information: Prime Time Head Start at Jeanerette

Report Number: 25-297-0022
Report Date: 11/10/2025

Sample Results

1-1-KIT-KF(L)-P

Date Collected 10/24/2025 07:00 **WPA Lab No** 76441
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/04/2025 14:00	L848989	EPA-200.8	50 mL	1	11/5/2025 17:19:16	JTR	L849478

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	1.09	0.500	µg/L

1-1-KIT-KF(R)-P

Date Collected 10/24/2025 07:02 **WPA Lab No** 76442
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/04/2025 14:00	L848989	EPA-200.8	50 mL	1	11/5/2025 17:21:51	JTR	L849478

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	0.557	0.500	µg/L

1-1-103-CF-P

Date Collected 10/24/2025 07:04 **WPA Lab No** 76443
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/04/2025 14:00	L848989	EPA-200.8	50 mL	1	11/5/2025 17:31:06	JTR	L849478

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	3.56	0.500	µg/L

Qualifiers/Definitions

MDL Method Detection Limit

MQL Method Quantitation Limit

Project Information: Prime Time Head Start at Jeanerette

Report Number: 25-297-0022
Report Date: 11/10/2025

Sample Results

1-1-FAC111A-F-P

Date Collected 10/24/2025 07:06 **WPA Lab No** 76444
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/04/2025 14:00	L848989	EPA-200.8	50 mL	1	11/5/2025 17:33:41	JTR	L849478

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	0.513	0.500	µg/L

1-1-104-CF-P

Date Collected 10/24/2025 07:08 **WPA Lab No** 76445
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/04/2025 14:00	L848989	EPA-200.8	50 mL	1	11/5/2025 17:36:17	JTR	L849478

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	2.32	0.500	µg/L

1-1-105-CF-P

Date Collected 10/24/2025 07:10 **WPA Lab No** 76446
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/04/2025 14:00	L848989	EPA-200.8	50 mL	1	11/5/2025 17:38:53	JTR	L849478

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	0.710	0.500	µg/L

Qualifiers/Definitions

MDL Method Detection Limit

MQL Method Quantitation Limit

Project Information: Prime Time Head Start at Jeanerette

Report Number: 25-297-0022
Report Date: 11/10/2025

Sample Results

1-1-106-CF-P

Date Collected 10/24/2025 07:12 **WPA Lab No** 76447
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 09:26:45	BKN	L849588

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	1.13	0.500	µg/L

1-1-107-CF-P

Date Collected 10/24/2025 07:14 **WPA Lab No** 76448
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 09:29:17	BKN	L849588

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	2.33	0.500	µg/L

1-1-GBath115-BF(L)-P

Date Collected 10/24/2025 07:16 **WPA Lab No** 76449
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 09:31:49	BKN	L849588

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	1.07	0.500	µg/L

Qualifiers/Definitions

MDL Method Detection Limit

MQL Method Quantitation Limit

Project Information: Prime Time Head Start at Jeanerette

Report Number: 25-297-0022
Report Date: 11/10/2025

Sample Results

1-1-BBath116-BF-P

Date Collected 10/24/2025 07:18 **WPA Lab No** 76450
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 09:34:22	BKN	L849588

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	2.66	0.500	µg/L

1-1-110-CF-P

Date Collected 10/24/2025 07:20 **WPA Lab No** 76451
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 09:36:54	BKN	L849588

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	4.16	0.500	µg/L

1-1-112-CF-P

Date Collected 10/24/2025 07:22 **WPA Lab No** 76452
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 09:44:33	BKN	L849588

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	6.27	0.500	µg/L

Qualifiers/Definitions

MDL Method Detection Limit

MQL Method Quantitation Limit

Project Information: Prime Time Head Start at Jeanerette

Report Number: 25-297-0022
Report Date: 11/10/2025

Sample Results

1-1-114-CF-P

Date Collected 10/24/2025 07:24 **WPA Lab No** 76453
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 09:47:03	BKN	L849588

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	5.45	0.500	µg/L

1-1-HAL(by126/127)-BF(L)-P

Date Collected 10/24/2025 07:26 **WPA Lab No** 76454
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 09:49:34	BKN	L849588

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	0.643	0.500	µg/L

Qualifiers/Definitions

MDL Method Detection Limit

ML Method Quantitation Limit

Quality Control Data

Client ID: Matrix New World Engineering
Project Description: Prime Time Head Start at Jeanerette
Report No: 25-297-0022

QC Prep: L848989 **QC Analytical Batch(es):** L849478
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L848989 Matrix: AQU
Associated Lab Samples: 76441, 76442, 76443, 76444, 76445, 76446

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	11/05/25 16:53

Laboratory Control Sample LCS-L848989

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	49.0	98.0	85-115

Matrix Spike & Matrix Spike Duplicate A 76446-MS-L848989 A 76446-MSD-L848989

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	0.710	50.5	50.5	50.7	52.0	99.0	102	70-130	2.5	20.0

Quality Control Data

Client ID: Matrix New World Engineering
Project Description: Prime Time Head Start at Jeanerette
Report No: 25-297-0022

QC Prep: L849182 **QC Analytical Batch(es):** L849588
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L849182 Matrix: AQU
Associated Lab Samples: 76447, 76448, 76449, 76450, 76451, 76452, 76453, 76454

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	11/06/25 09:09

Laboratory Control Sample LCS-L849182

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	49.0	98.0	85-115

Matrix Spike & Matrix Spike Duplicate A 76461-MS-L849182 A 76461-MSD-L849182

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	< 0.505	50.5	50.5	45.4	46.3	90.0	92.0	70-130	1.9	20.0

Shipment Receipt Form

Customer Number: **01312**
 Customer Name: **Matrix New World Engineering**
 Report Number: **25-297-0022**

Shipping Method

Fed Ex US Postal Lab Other :
 UPS Client Courier Thermometer ID:

Shipping container/cooler uncompromised?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Number of coolers/boxes received	<input type="text" value="1"/>		
Custody seals intact on shipping container/cooler?	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> Not Present
Custody seals intact on sample bottles?	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> Not Present
Chain of Custody (COC) present?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
COC agrees with sample label(s)?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
COC properly completed	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Samples in proper containers?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Sample containers intact?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Sufficient sample volume for indicated test(s)?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
All samples received within holding time?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Cooler temperature in compliance?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> Not Present
Cooler/Samples arrived at the laboratory on ice. Samples were considered acceptable as cooling process had begun.	<input type="radio"/> Yes	<input checked="" type="radio"/> No	
Water - Sample containers properly preserved	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A
Water - Sulfuric containers verified pH <2	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
Water - VOA vials free of headspace	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
Trip Blanks received with VOAs	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
Soil VOA method 5035 – compliance criteria met	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
<input type="checkbox"/> High concentration container (48 hr)		<input type="checkbox"/> Low concentration EnCore samplers (48 hr)	
<input type="checkbox"/> High concentration pre-weighed (methanol -14 d)		<input type="checkbox"/> Low conc pre-weighed vials (Sod Bis -14 d)	
Special precautions or instructions included?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	

Comments:

Signature:

Date & Time:



Kit ID:	292599
Initiated By:	Amy Jackson
Initiated Date:	10/17/2025
Project Comment	Primary

CHAIN-OF-CUSTODY



Matrix New World Engineering
 Prime Time Head Start at Jeanerette

25-297-0022
 01312
 10-24-2025
 13:48:12

Company Name	Company Number	Client Project Manager/Contact	Purchase Order Number
Matrix New World Engineering	01312	Maggie Turner	25-0710
Site Name	Project Number	<input type="checkbox"/> RUSH – Additional charges apply <input type="checkbox"/> Special Detection Limits(s) Date Results Needed	Method of Shipment <input type="checkbox"/> Fed Ex <input type="checkbox"/> UPS <input type="checkbox"/> USPS <input type="checkbox"/> Courier <input type="checkbox"/> Client Drop Off Other
Prime Time Head Start at Jeanerette	25-0710		
LIMS Project ID	Project Manager Phone #	Project Manager Email	Site/Facility ID #
Matrix-HS Lead DW		mturner@mnwe.com	

Date	Time	Sample ID	Matrix	Grab/Comp	# of Cont	Container Type	Preservation	Analyses
10/24/2025	7:00	1-1-KIT-KF(L)-P 76441	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:02	1-1-KIT-KF(R)-P 76442	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:04	1-1-103-CF-P 76443	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:06	1-1-FAC111A-F-P 76444	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:08	1-1-104-CF-P 76445	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:10	1-1-105-CF-P 76446	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:12	1-1-106-CF-P 76447	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW

For Laboratory Use Only			Sampled by (Name - Print)		Client Remarks/Comments			
Ice	Custody Seals	Lab Comments	Cassie Aplin					
Y/N	Y/N		Relinquished by: (SIGNATURE)	Date Time	Received by: (SIGNATURE)	Date Time		
			Cassie Aplin	10/24/25 9:50	[Signature]	10/24/25 0950		
			Relinquished by: (SIGNATURE)	Date Time	Received by: (SIGNATURE)	Date Time		
Blank/Cooler Temp			[Signature]	10/24/25 1300	Brand Hidalgo	10-24-25 1300		
Ambient			Relinquished by: (SIGNATURE)	Date Time	Received by: (SIGNATURE)	Date Time		



Kit ID:	292599
Initiated By:	Amy Jackson
Initiated Date:	10/17/2025
Project Comment	Primary

CHAIN-OF-CUSTODY

Company Name	Company Number	Client Project Manager/Contact	Purchase Order Number
Matrix New World Engineering	01312	Maggie Turner	25-0710
Site Name	Project Number	<input type="checkbox"/> RUSH – Additional charges apply <input type="checkbox"/> Special Detection Limits(s) Date Results Needed	Method of Shipment <input type="checkbox"/> Fed Ex <input type="checkbox"/> UPS <input type="checkbox"/> USPS <input type="checkbox"/> Courier <input type="checkbox"/> Client Drop Off Other
Prime Time Head Start at Jeanerette	25-0710		
LIMS Project ID	Project Manager Phone #	Project Manager Email	Site/Facility ID #
Matrix-HS Lead DW		mtturner@mnwe.com	

Date	Time	Sample ID	Matrix	Grab/Comp	# of Cont	Container Type	Preservation	Analyses
10/24/2025	7:14	1-1-107-CF-P 76448	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:16	1-1-GBath115-BF(L)-P 76449	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:18	1-1-BBath116-BF-P 76450	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:20	1-1-110-CF-P 76451	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:22	1-1-112-CF-P 76452	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:24	1-1-114-CF-P 76453	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:26	1-1-HAL(by126/127)-BF(L)-P 76454	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW

For Laboratory Use Only			Sampled by (Name - Print)	Client Remarks/Comments				
Ice	Custody Seals	Lab Comments	Cassie Aplin	Date	Time	Received by: (SIGNATURE)	Date	Time
Y/N	Y/N		Relinquished by: (SIGNATURE)	10/24/25	9:50	<i>[Signature]</i>	10/24/25	09:50
			Relinquished by: (SIGNATURE)			<i>[Signature]</i>	10-24-25	1300
			Relinquished by: (SIGNATURE)			<i>[Signature]</i>		
Blank/Cooler Temp				Date	Time	Received by: (SIGNATURE)	Date	Time
Ambient						Brand Hidalgo		



CHAIN-OF-CUSTODY

Kit ID: 292599
Initiated By: Amy Jackson
Initiated Date: 10/17/2025
Project Comment Primary

Company Name Matrix New World Engineering	Company Number 01312	Client Project Manager/Contact Maggie Turner	Purchase Order Number 25-0710
Site Name Prime Time Head Start at Jeanerette	Project Number 25-0710	<input type="checkbox"/> RUSH – Additional charges apply <input type="checkbox"/> Special Detection Limits(s) Date Results Needed	Method of Shipment <input type="checkbox"/> Fed Ex <input type="checkbox"/> UPS <input type="checkbox"/> USPS <input type="checkbox"/> Courier <input type="checkbox"/> Client Drop Off Other
LIMS Project ID Matrix-HS Lead DW	Project Manager Phone #	Project Manager Email mtturner@mnwe.com	Site/Facility ID #

Date	Time	Sample ID	Matrix	Grab/Comp	# of Cont	Container Type	Preservation	Analyses
10/21/2025	7:28	1-1-132-F-P fixture removed	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/21/25	7:50	1-1-132-SB-P fixture removed	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW

For Laboratory Use Only			Sampled by (Name - Print)	Client Remarks/Comments				
Ice Y/N <input checked="" type="radio"/>	Custody Seals Y/N <input checked="" type="radio"/>	Lab Comments	Cassie Aplin	Date	Time	Received by: (SIGNATURE)	Date	Time
			Relinquished by: (SIGNATURE) Cassie Aplin	10/21/25	9:50	[Signature]	10/24/25	09:50
			Relinquished by: (SIGNATURE) [Signature]			Received by: (SIGNATURE) Brand Hidalgo	10-24-25	1300
			Relinquished by: (SIGNATURE)			Received by: (SIGNATURE)		
Blank/Cooler Temp Ambient				Date	Time		Date	Time



11/10/2025

Matrix New World Engineering
Ms. Dawn Brown
6717 Complex Drive
Baton Rouge, LA, 70809

Ref: Report Number: 25-297-0023
Project Description: Prime Time Head Start at Jeanerette

Dear Ms. Dawn Brown:

Waypoint Analytical Louisiana, Inc. received sample(s) on 10/24/2025 for the analyses presented in the following report. The above referenced project has been analyzed per your instructions. Unless otherwise noted, the analyses were performed in our laboratory in accordance with Standard Methods, The Solid Waste Manual SW-846, EPA Methods for Chemical Analysis of Water and Wastes and /or 40 CFR part 136.

Certain parameters (chlorine, pH, dissolved oxygen, sulfite...) are required to be analyzed within 15 minutes of sampling. Usually, but not always, any field parameter analyzed at the laboratory is outside of this holding time. Refer to sample analysis time for confirmation of holding time compliance. Analyses reported which indicate "Field" for these parameters were analyzed by the client in the field. Results for solid samples are reported on an as received or "wet weight" basis unless otherwise specified.

The analytical data has been validated using standard quality control measures performed as required by the analytical method. Quality Assurance, method validations, instrumentation maintenance and calibration for all parameters (NELAP and non-NELAP) were performed in accordance with guidelines established by the USEPA (including 40 CFR 136 Method Update Rule May 2021) and NELAC unless otherwise indicated. Any parameter for which the laboratory is not officially NELAP accredited is indicated by a '~' symbol. These are not included in the scope because NELAP accreditation is either not available or has not been applied for. Additional certifications may be held/are available for parameters, where NELAP accreditation is not required or applicable. A full list of certifications is available upon request.

All quality control measures undertaken in accordance with Waypoint Analytical Louisiana, Inc. CompQAP990807A and revisions under the terms of the Louisiana Environmental Laboratory Accreditation Program (Certificate #02041) are within acceptance ranges established in that document with the exception of the items indicated and/or discussed in a Case Narrative.

The results are shown on the attached analysis sheet(s). Be aware that the time analyzed for certain samples (e.g. - BOD, CBOD, etc.) refer to the time the sample batch was begun and not necessarily to the time an individual sample was begun. Thank you for allowing Waypoint Analytical Louisiana, Inc. to serve you. Should I be of further assistance, if you have any questions or need additional information please contact me or client services.

Sincerely,

Amy Jackson
Project Manager

Laboratory's liability in any claim relating to analyses performed shall be limited to, at laboratory's option, repeating the analysis in question at laboratory's expense, or the refund of the charges paid for performance of said analysis. This report may be reproduced in full only with the written permission of the laboratory and/or the entity to which it is addressed. Results contained herein relate only to the sample(s) submitted to the laboratory.



Certification Summary

Laboratory ID: WP MLA: Waypoint Analytical Louisiana, Inc., Marrero, LA

State	Program	Lab ID	Expiration Date
Georgia	State Program	02041	06/30/2026
Louisiana	State Program - NELAP	02041	06/30/2026

Laboratory ID: WP MTN: Waypoint Analytical, LLC. (Memphis), Memphis, TN

State	Program	Lab ID	Expiration Date
Alabama	State Program	40750	11/04/2025
Arkansas	State Program	88-00650	02/06/2026
California	State Program	2904	06/30/2026
Florida	State Program - NELAP	E871157	06/30/2026
Georgia	State Program	C044	11/14/2025
Georgia	State Program	04015	06/30/2025
Illinois	State Program - NELAP	200078	10/31/2026
Kentucky	State Program	KY90047	12/31/2025
Kentucky	State Program	80215	06/30/2026
Kentucky	State Program	KY90047	12/31/2025
Louisiana	State Program - NELAP	LA037	12/31/2025
Louisiana	State Program - NELAP	04015	06/30/2026
Mississippi	State Program	MS	11/14/2025
North Carolina	State Program	47701	07/31/2026
North Carolina	State Program	415	12/31/2025
Oklahoma	State Program - NELAP	9311	12/31/2025
Pennsylvania	State Program - NELAP	68-03195	05/31/2026
South Carolina	State Program	84002	06/30/2026
Tennessee	State Program	02027	08/11/2028
Texas	State Program - NELAP	T104704180	09/30/2026
Virginia	State Program	00106	06/30/2026
Virginia	State Program - NELAP	460181	09/30/2026

Sample Summary Table

Report Number: 25-297-0023
Client Project Description: Prime Time Head Start at Jeanerette

Lab No	Client Sample ID	Matrix	Date Collected	Date Received	Method	Lab ID
76455	1-1-KIT-KF(L)-F	Aqueous	10/24/2025 07:01	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76456	1-1-KIT-KF(R)-F	Aqueous	10/24/2025 07:03	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76457	1-1-103-CF-F	Aqueous	10/24/2025 07:05	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76458	1-1-FAC111A-F-F	Aqueous	10/24/2025 07:07	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76459	1-1-104-CF-F	Aqueous	10/24/2025 07:09	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76460	1-1-105-CF-F	Aqueous	10/24/2025 07:11	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76461	1-1-106-CF-F	Aqueous	10/24/2025 07:13	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76462	1-1-107-CF-F	Aqueous	10/24/2025 07:15	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76463	1-1-GBath115-BF(L)-F	Aqueous	10/24/2025 07:17	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76464	1-1-BBath116-BF-F	Aqueous	10/24/2025 07:19	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76465	1-1-110-CF-F	Aqueous	10/24/2025 07:21	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76466	1-1-112-CF-F	Aqueous	10/24/2025 07:23	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76467	1-1-114-CF-F	Aqueous	10/24/2025 07:25	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN
76468	1-1-HAL(by126/127)-BF(L)-F	Aqueous	10/24/2025 07:27	10/24/2025 13:00	EPA-200.8 (DW)	WP MTN

Summary of Detected Analytes

Project: Prime Time Head Start at Jeanerette

Report Number: 25-297-0023

Client Sample ID Method	Lab Sample ID Parameters	Result	Units	Report Limit	Analyzed	Qualifiers
1-1-KIT-KF(L)-F	A 76455					
EPA-200.8 (DW)	Lead	1.33	µg/L	0.500	11/06/2025 09:52	
1-1-KIT-KF(R)-F	A 76456					
EPA-200.8 (DW)	Lead	0.558	µg/L	0.500	11/06/2025 09:54	
1-1-GBath115-BF(L)-F	A 76463					
EPA-200.8 (DW)	Lead	0.744	µg/L	0.500	11/06/2025 10:28	
1-1-BBath116-BF-F	A 76464					
EPA-200.8 (DW)	Lead	2.16	µg/L	0.500	11/06/2025 10:31	
1-1-112-CF-F	A 76466					
EPA-200.8 (DW)	Lead	0.536	µg/L	0.500	11/06/2025 10:36	

Project Information: Prime Time Head Start at Jeanerette

Report Number: 25-297-0023
Report Date: 11/10/2025

Sample Results

1-1-KIT-KF(L)-F

Date Collected 10/24/2025 07:01 **WPA Lab No** 76455
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 09:52:04	BKN	L849588

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	1.33	0.500	µg/L

1-1-KIT-KF(R)-F

Date Collected 10/24/2025 07:03 **WPA Lab No** 76456
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 09:54:36	BKN	L849588

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	0.558	0.500	µg/L

1-1-103-CF-F

Date Collected 10/24/2025 07:05 **WPA Lab No** 76457
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 09:57:07	BKN	L849588

CAS#	Parameter	Result	ML	Units
7439-92-1	Lead	ND	0.500	µg/L

Qualifiers/Definitions
 J Estimated value
 MQL Method Quantitation Limit
 MDL Method Detection Limit

Project Information: Prime Time Head Start at Jeanerette

Report Number: 25-297-0023
Report Date: 11/10/2025

Sample Results

1-1-FAC111A-F-F

Date Collected 10/24/2025 07:07 **WPA Lab No** 76458
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 09:59:39	BKN	L849588

CAS#	Parameter	Result	MQL	Units
7439-92-1	Lead	ND	0.500	µg/L

1-1-104-CF-F

Date Collected 10/24/2025 07:09 **WPA Lab No** 76459
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 10:02:12	BKN	L849588

CAS#	Parameter	Result	MQL	Units
7439-92-1	Lead	ND	0.500	µg/L

1-1-105-CF-F

Date Collected 10/24/2025 07:11 **WPA Lab No** 76460
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 10:04:44	BKN	L849588

CAS#	Parameter	Result	MQL	Units
7439-92-1	Lead	ND	0.500	µg/L

Qualifiers/Definitions
 J Estimated value
 MQL Method Quantitation Limit
 MDL Method Detection Limit

Project Information: Prime Time Head Start at Jeanerette

Report Number: 25-297-0023
Report Date: 11/10/2025

Sample Results

1-1-106-CF-F

Date Collected 10/24/2025 07:13 **WPA Lab No** 76461
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849182	EPA-200.8	50 mL	1	11/6/2025 10:07:16	BKN	L849588

CAS#	Parameter	Result	MQL	Units
7439-92-1	Lead	ND	0.500	µg/L

1-1-107-CF-F

Date Collected 10/24/2025 07:15 **WPA Lab No** 76462
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849184	EPA-200.8	50 mL	1	11/6/2025 10:26:28	BKN	L849588

CAS#	Parameter	Result	MQL	Units
7439-92-1	Lead	ND	0.500	µg/L

1-1-GBath115-BF(L)-F

Date Collected 10/24/2025 07:17 **WPA Lab No** 76463
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849184	EPA-200.8	50 mL	1	11/6/2025 10:28:59	BKN	L849588

CAS#	Parameter	Result	MQL	Units
7439-92-1	Lead	0.744	0.500	µg/L

Qualifiers/Definitions
 J Estimated value
 MQL Method Quantitation Limit
 MDL Method Detection Limit

Project Information: Prime Time Head Start at Jeanerette

Report Number: 25-297-0023
Report Date: 11/10/2025

Sample Results

1-1-BBath116-BF-F

Date Collected 10/24/2025 07:19 **WPA Lab No** 76464
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849184	EPA-200.8	50 mL	1	11/6/2025 10:31:31	BKN	L849588

CAS#	Parameter	Result	MQL	Units
7439-92-1	Lead	2.16	0.500	µg/L

1-1-110-CF-F

Date Collected 10/24/2025 07:21 **WPA Lab No** 76465
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849184	EPA-200.8	50 mL	1	11/6/2025 10:34:03	BKN	L849588

CAS#	Parameter	Result	MQL	Units
7439-92-1	Lead	ND	0.500	µg/L

1-1-112-CF-F

Date Collected 10/24/2025 07:23 **WPA Lab No** 76466
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849184	EPA-200.8	50 mL	1	11/6/2025 10:36:35	BKN	L849588

CAS#	Parameter	Result	MQL	Units
7439-92-1	Lead	0.536	0.500	µg/L

Qualifiers/Definitions	J	Estimated value	MDL	Method Detection Limit
	MQL	Method Quantitation Limit		

Project Information: Prime Time Head Start at Jeanerette

Report Number: 25-297-0023
Report Date: 11/10/2025

Sample Results

1-1-114-CF-F

Date Collected 10/24/2025 07:25 **WPA Lab No** 76467
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849184	EPA-200.8	50 mL	1	11/6/2025 10:39:07	BKN	L849588

CAS#	Parameter	Result	SQL	Units
7439-92-1	Lead	ND	0.500	µg/L

1-1-HAL(by126/127)-BF(L)-F

Date Collected 10/24/2025 07:27 **WPA Lab No** 76468
Date Received 10/24/2025 13:00 **Matrix** Aqueous

EPA-200.8 (DW)

Prep Date	Prep Batch	Prep Method	Sample	Dilution	Analysis Date	By	Analytical Batch
11/05/2025 12:00	L849184	EPA-200.8	50 mL	1	11/6/2025 10:48:16	BKN	L849588

CAS#	Parameter	Result	SQL	Units
7439-92-1	Lead	ND	0.500	µg/L

Qualifiers/Definitions

J Estimated value
MQL Method Quantitation Limit

MDL Method Detection Limit

Quality Control Data

Client ID: Matrix New World Engineering
Project Description: Prime Time Head Start at Jeanerette
Report No: 25-297-0023

QC Prep: L849182 **QC Analytical Batch(es):** L849588
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L849182 Matrix: AQU
Associated Lab Samples: 76455, 76456, 76457, 76458, 76459, 76460, 76461

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	11/06/25 09:09

Laboratory Control Sample LCS-L849182

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	49.0	98.0	85-115

Matrix Spike & Matrix Spike Duplicate A 76461-MS-L849182 A 76461-MSD-L849182

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	< 0.505	50.5	50.5	45.4	46.3	90.0	92.0	70-130	1.9	20.0

Quality Control Data

Client ID: Matrix New World Engineering
Project Description: Prime Time Head Start at Jeanerette
Report No: 25-297-0023

QC Prep: L849184 **QC Analytical Batch(es):** L849588
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L849184 Matrix: AQU
Associated Lab Samples: 76462, 76463, 76464, 76465, 76466, 76467, 76468

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	11/06/25 10:43

Laboratory Control Sample LCS-L849184

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	47.3	95.0	85-115

Matrix Spike & Matrix Spike Duplicate A 76685-MS-L849184 A 76685-MSD-L849184

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	15.5	50.5	50.5	59.5	61.1	87.0	90.0	70-130	2.6	20.0

Shipment Receipt Form

Customer Number: **01312**

Customer Name: **Matrix New World Engineering**

Report Number: **25-297-0023**

Shipping Method

Fed Ex US Postal Lab Other :
 UPS Client Courier Thermometer ID:

Shipping container/cooler uncompromised?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Number of coolers/boxes received	<input type="text" value="1"/>		
Custody seals intact on shipping container/cooler?	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> Not Present
Custody seals intact on sample bottles?	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> Not Present
Chain of Custody (COC) present?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
COC agrees with sample label(s)?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
COC properly completed	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Samples in proper containers?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Sample containers intact?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Sufficient sample volume for indicated test(s)?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
All samples received within holding time?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Cooler temperature in compliance?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> Not Present
Cooler/Samples arrived at the laboratory on ice. Samples were considered acceptable as cooling process had begun.	<input type="radio"/> Yes	<input checked="" type="radio"/> No	
Water - Sample containers properly preserved	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A
Water - Sulfuric containers verified pH <2	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
Water - VOA vials free of headspace	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
Trip Blanks received with VOAs	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
Soil VOA method 5035 – compliance criteria met	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
<input type="checkbox"/> High concentration container (48 hr)		<input type="checkbox"/> Low concentration EnCore samplers (48 hr)	
<input type="checkbox"/> High concentration pre-weighed (methanol -14 d)		<input type="checkbox"/> Low conc pre-weighed vials (Sod Bis -14 d)	
Special precautions or instructions included?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	

Comments:

Signature:

Date & Time:



Kit ID:	292602
Initiated By:	Amy Jackson
Initiated Date:	10/17/2025
Project Comment	Flush

CHAIN-OF-CUSTODY



Matrix New World Engineering
 Prime Time Head Start at Jeanerette

25-297-0023
 01312
 10-24-2025
 13:50:05

Company Name	Company Number	Client Project Manager/Contact	Purchase Order Number
Matrix New World Engineering	01312	Maggie Turner	25-0710
Site Name	Project Number	<input type="checkbox"/> RUSH – Additional charges apply <input type="checkbox"/> Special Detection Limits(s) Date Results Needed	Method of Shipment <input type="checkbox"/> Fed Ex <input type="checkbox"/> UPS <input type="checkbox"/> USPS <input type="checkbox"/> Courier <input type="checkbox"/> Client Drop Off Other
Prime Time Head Start at Jeanerette	25-0710		
LIMS Project ID	Project Manager Phone #	Project Manager Email	Site/Facility ID #
Matrix-HS Lead DW		mturner@mnwe.com	

Date	Time	Sample ID	Matrix	Grab/Comp	# of Cont	Container Type	Preservation	Analyses
10/21/2025	7:01	1-1-KIT-KF(L)-F 76455	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/21/25	7:03	1-1-KIT-KF(R)-F 76456	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/21/25	7:05	1-1-103-CF-F 76457	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/21/25	7:07	1-1-FAC111A-F-F 76458	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/21/25	7:09	1-1-104-CF-F 76459	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/21/25	7:11	1-1-105-CF-F 76460	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/21/25	7:13	1-1-106-CF-F 76461	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW

For Laboratory Use Only			Sampled by (Name - Print)	Client Remarks/Comments				
Ice	Custody Seals	Lab Comments	Cassie Apelin	Date	Time	Received by: (SIGNATURE)	Date	Time
Y/N	Y/N		Relinquished by: (SIGNATURE)	10/21/25	9:50	[Signature]	10/24/25	0950
			Relinquished by: (SIGNATURE)			[Signature]	10-24-25	1300
			Relinquished by: (SIGNATURE)			[Signature]		
Blank/Cooler Temp						Brand Hidalgo		
Ambient								



Kit ID:	292602
Initiated By:	Amy Jackson
Initiated Date:	10/17/2025
Project Comment	Flush

CHAIN-OF-CUSTODY

Company Name	Company Number	Client Project Manager/Contact	Purchase Order Number
Matrix New World Engineering	01312	Maggie Turner	25-0710
Site Name	Project Number	<input type="checkbox"/> RUSH – Additional charges apply <input type="checkbox"/> Special Detection Limits(s) Date Results Needed	Method of Shipment <input type="checkbox"/> Fed Ex <input type="checkbox"/> UPS <input type="checkbox"/> USPS <input type="checkbox"/> Courier <input type="checkbox"/> Client Drop Off Other
Prime Time Head Start at Jeanerette	25-0710		
LIMS Project ID	Project Manager Phone #	Project Manager Email	Site/Facility ID #
Matrix-HS Lead DW		mturner@mnwe.com	

Date	Time	Sample ID	Matrix	Grab/Comp	# of Cont	Container Type	Preservation	Analyses
10/24/2025	7:15	1-1-107-CF-F <i>76462</i>	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:17	1-1-GBath115-BF(L)-F <i>76463</i>	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:19	1-1-BBath116-BF-F <i>76464</i>	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:21	1-1-110-CF-F <i>76465</i>	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:23	1-1-112-CF-F <i>76466</i>	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:25	1-1-114-CF-F <i>76467</i>	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/24/25	7:27	1-1-HAL(by126/127)-BF(L)-F <i>76468</i>	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW

For Laboratory Use Only		Sampled by (Name - Print)	Client Remarks/Comments					
Ice	Custody Seals	<i>Cassie Apin</i>	Date	Time	Received by: (SIGNATURE)	Date	Time	
Y/N <input checked="" type="checkbox"/>	Y/N <input checked="" type="checkbox"/>		Relinquished by: (SIGNATURE)	10/24/25	9:50	<i>[Signature]</i>	10/24/25	0950
Blank/Cooler Temp			Relinquished by: (SIGNATURE)	Date	Time	Received by: (SIGNATURE)	Date	Time
<i>Ambient</i>			<i>[Signature]</i> 10/24/25 1300			<i>[Signature]</i>	10-24-25	1300
		Relinquished by: (SIGNATURE)	Date	Time	Received by: (SIGNATURE)	Date	Time	



Kit ID:	292602
Initiated By:	Amy Jackson
Initiated Date:	10/17/2025
Project Comment	Flush

CHAIN-OF-CUSTODY

Company Name		Company Number		Client Project Manager/Contact			Purchase Order Number		
Matrix New World Engineering		01312		Maggie Turner			25-0710		
Site Name		Project Number		<input type="checkbox"/> RUSH – Additional charges apply <input type="checkbox"/> Special Detection Limits(s) Date Results Needed			Method of Shipment <input type="checkbox"/> Fed Ex <input type="checkbox"/> UPS <input type="checkbox"/> USPS <input type="checkbox"/> Courier <input type="checkbox"/> Client Drop Off Other		
Prime Time Head Start at Jeanerette		25-0710							
LIMS Project ID		Project Manager Phone #		Project Manager Email			Site/Facility ID #		
Matrix-HS Lead DW				mtturner@mnwe.com					

Date	Time	Sample ID	Matrix	Grab/Comp	# of Cont	Container Type	Preservation	Analyses
10/21/2025	7:29	1-1-132-F-F Fixture removed	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW
10/21/25	7:31	1-1-132-SB-F Fixture removed	Aqueous	G	1	Plastic - 250ml	HNO3 - Nitric Acid	200.8 - Lead in DW

For Laboratory Use Only			Sampled by (Name - Print)	Client Remarks/Comments					
Ice	Custody Seals	Lab Comments	Cassie Aguirre	Date	Time	Received by: (SIGNATURE)	Date	Time	
Y/N	Y/N		Relinquished by: (SIGNATURE)	10/24/25	9:50	<i>[Signature]</i>	10/24/25	0850	
Blank/Cooler Temp			Relinquished by: (SIGNATURE)	<i>[Signature]</i>	Date	Time	Received by: (SIGNATURE)	Date	Time
Ambient			Relinquished by: (SIGNATURE)	<i>[Signature]</i>	10/24/25	1300	Brandi Hidalgo	10-24-25	1300